





REGIONE AUTÓNOMA DE SARDIGNA REGIONE AUTONOMA DELLA SARDEGNA



Non-revenue Water Management in Amman: a Case Study of Yadoudeh Area Online Workshop , 16 December 2020

Prof. Radwan Al-Weshah Professor of Hydrology and Water Engineering Dean of Scientific Research/Member of Civil Engineering Division, JEA The University of Jordan











REGIONE AUTONOMA DE SARDIGNA REGIONE AUTONOMA DELLA SARDEGNA





- Methodology
- **Results and Discussion**
- **Conclusion and Recommendations**









REGIONE AUTÒNOMA DE SARDIGNA REGIONE AUTONOMA DELLA SARDEGNA

NAWAMED

Introduction







Introduction

NAWAMED

Non-revenue water (NRW) is expected to be as one of the extensive challenges that Jordan water sector faces. Jordan is among the world poorest water country.

The study aims to reduce NRW in Amman by taking Yadoudeh distribution area (DZ 33) as a case of study.

DZ33 has an area of 36.5 km² and located in the Southern part of Amman. The water supply system is intermittent with approximately 9175 customers currently being serviced by Miyahuna. The topography of the area is very complex encompassing hilly and low areas.













- Assess of the existing NRW;
- Quantify the real losses and apparent losses in Yadoudeh distribution network; and
- Recommend an integrated NRW management in Amman distribution system.







REGIONE AUTONOMA DE SARDIGNA REGIONE AUTONOMA DELLA SARDEGNA



Methodology







The methodology includes

- Data collection of different water supply sources
- Analysis and modeling of NRW using Water GEMS software
- Analysis and modeling of NRW using applicable IWA tools
- Testing NRW options and management tools
- Developing the guidelines and best management practices to reduce NRW in the study area and Jordan.









Water network analysis and hydraulic modeling using Water GEMS software

For the study of DZ 33 Yadoudeh network, the following are points needed to be realized:

Collecting all the needed data related to the water distribution network in this area:

- Main sources with elevations : Reservoirs , Pumps , Towers
- Full Existing network with clear connections &fittings: Primary, Secondary and Tertiary Pipes (connection nodes, valves, PRVs,.....(shp. file))
- Borders for Existing DMAs with names(shp. file)
- Base map including names of main streets and landmarks.
- No. of customers within DZ 33 border.
- Amount of water supply and Consumption.
- Contour map or any Topographic data to recognize the elevations in DZ33.









Analysis of Existing data includes:

- Topography of the area (Elevations analysis for the max. &min. elevations), taking in to consideration the elevation of source for each DMA.
- Determine main pipes supply DZ 33.
- Create elevation diagram for the existing system.
- Create existing and proposed hydraulic model for the area.
- Start thinking of solutions upon the results of hydraulic analysis & according to design criteria.
- Create elevation diagram for the proposed system.







Modeling of NRW using applicable EPA and AWWA tools

AWWA free audit water software

Figure below represents IWA 'Best Practice' Water Balance and Terminology

		Billed	Billed Metered Consumption	Revenue				
	Authorized	Consumption	Billed Unmetered Consumption	Water				
System Input Volume	Consumption	Unbilled Authorized	Unbilled Metered Consumption		2			
		Consumption	Unbilled Unmetered Consumption		-			
		Apparent	Unauthorized Consumption					
		Losses	Metering Inaccuracies and Data Handling Errors	Non-Revenue Water				
	Water Losses		Leakage on Transmission and/or Distribution Mains		1.25			
		Real Losses	Leakae and Overflows at Utility's Storage Tanks					
			Leakage on Service Connections up to Point of Customer Metering					









Real loss component analysis model

- This model is used to provide the water authorities with a utility-tested software tool to assure a leakage component analysis.
- Also it is used to identify economic options for the reduction of real loss, through enhance the speed and the quality of leak repair, proactive leak detection and pressure management.
- This model also was used to help water authorities in evaluating options for implementing sustainable leaks control programs.







REGIONE AUTONOMA DE SARDIGNA REGIONE AUTONOMA DELLA SARDEGNA



Results and Discussion







Non-revenue water reduction in Amman: a case study of Yadoudeh area

NAWAMED

Some preliminary analysis are shown below according to the complaints, control and communication center from 2017 to 2018. Most of the received complaints are documented as pipe blockage. High significant pipe blockage in the network are an indicator of low efficiency and the condition of the system.

DZ	Water	Leaks	Pipe Bl	ockage	H	C	Main Pipe		
	2017	2018	2017	2018	2017	2018	2017	2018	
33A	64	29	123	54	19	6	12	1	
33B	26	25	19	96	8	12	5	1	
33C1	135	301	108	504	43	93	21	35	
33 C2		464		829		153		59	
33D1	1189	254	975	319	315	83	171	42	
33 D2		36		14		11		7	
33E	70	366	57	697	29	123	7	48	
33F	78	123	116	97	23	39	11	20	
33G	25	12	32	26	5	7	5	2	
33H	943	67	1410	150	259	22	147	7	
Sum.						549			







Non-revenue water reduction in Amman: a case study of Yadoudeh area

NAWAMED Water leaks per pipe diameter

Most of the water leaks occur in pipes diameter between 3/4 inch and 2 inch. These pipes usually used in water connections between main lines and the costumers.

Leaks per pipe material

According to the received data in the table, the poly ethylene pipe has the highest leaks frequencies

				18 18 18 18 18 18 18 18 18 18 18 18 18 1		
Diamet er (mm)	Diameter (in)	No. of complaints (Frequency) 2017	No. of complaints (Frequency) 2018	Material type	No of Complaints (Frequency) 2017	No of Complaints (Frequency) 2018
Dn 15	1/2	66	74	GI	197	157
Dn 20	3/4	459	407		137	F 40
Dn 25	1	75	41	PE	696	549
Dn 50	2	264	153	ST	12	7
Dn 100	4	31	25			_
Dn 150	6	1	4	Cast	0	0
Dn 200	8	0	3			•
Ot	her	2	1	PVC	0	0





Non-revenue water reduction in Amman: a case study of Yadoudeh area

NAWAMED

Based on the data that were collected from Miyahuna, three models are applied to find and audit NRW in Yadoudeh distribution network

Previous conditions

The DZ 33 was originally designed to include 8 hydraulic districts A,B,C,D,E,F,G and H all fed by Yadoudeh reservoir and tower.







Non-revenue water reduction in Amman: a case study of Yadoudeh area



Present Conditions (After Hydraulic modeling)

This Hydraulic model divided DZ-33 into Ten (10) districts, A, B, C1, C2, D1, D2, E.F, G and H.













The characteristics of the 10 districts in the Yadoudeh are listed as it is in the table

DMA Name	Customers	Area (km ²)	" As
33 A	1507	1.53	(Friday
33 B	1171	5.65	P
33 C1	1323	3.43	and a
33 C2	2099	6.58	-200
33 D1	974	2.42	0
33 D2	22	2	
33 E	1226	5.29	3
33 F	131	2.34	
33 G	334	2.54	00
33 H	388	0.19	3
Total	9175	31.97	







Distribution zone analysis and hydraulic modeling

In order to reduce of NRW in DZ-33 there area group of activities and corrective actions that are conducted as the following:

- Hydraulic analysis and computer modeling were conducted for DZ-33 including installing new feeders and redefining the distribution zone and districts boundaries.
- Procurement of pipes, fitting, and valves.
- Pipe rehabilitation work and residential water meter installation.
- Measurements and quantifications of NRW.
- Pressure management and control (Design & Implementation)
- Districts and distribution zone isolation (10 districts).







Elevations analysis of the proposed districts (original model)

DMA name	Customers	Highest Elevation (m)	Lowest Elevation(m)	Difference in Elevation Within District (m)	Reservoir. Elevation (m)	Tower Elevatio n(m)	Static Head (m) Max. Elevation	Static Head (m) Min. Elevation
33 A	1507	923	857	66		933.5	76.5	10.5
33 B	1171	882	852	30	911		59	29
33 C1	1323	893	838	55		933.5	95.5	40.5
33 C2	2099	850	812	38	911		99	61
33 D1	974	875	803	72	911		108	36
33 D2	22	890	816	74	911		95	21
33 E	1226	874	824	50	911		87	37
33 F	131	877	785	92	911		126	34
33 G	334	841	793	48	911		118	70
33 H	388	890	860	30		933.5	73.5	43.5
Total	9175							

3









Average & Peak Demand of DZ 33

As it's indicated in the table, we realize that the total average demand for DZ 33 463m3/hr.

	Average & Peak Demand of DZ 33													
DZ Name	Customers from GIS	No. of Persons	Population 2025	Current Demand (L/D)	Average Current Demand (m3/hr)	Peak Demand (m3/hr)	No. of Junctions	Ave. Demand/ Junction	Peak Demand/ Junction					
33 A	1507	8,138	9118	1823540	76	266	200	0.38	1.33					
33 B	1171	6,323	7085	1416964	59	207	147	0.40	1.41					
33 C1	1323	7,144	8004	1600891	00891 67		284	0.23	0.82					
33 C2	2099	11,34	12699	2539887	106	106 370		0.38	1.32					
33 D1	974	5,260	5893	1178585	49	172	155	0.32	1.11					
33 D2	22	119	133	26621	1	4	3	0.37	1.29					
33E	1226	6,620	7418	1483517	62	216	107	0.58	2.02					
33 F	131	707	793	158516	7	23	27	0.24	0.86					
33 G	334	1,804	2021	404155	17	59	65	0.26	0.91					
33 H	388	2,095	2347	469498	20	68	28	0.70	2.45					
Total	9,175				463	1619								







The schematic diagram of DZ33

NAWAMED

Figure show the primary and secondary main feeders for each district in DZ 33









REGIONE AUTÔNOMA DE SARDIGNA REGIONE AUTONOMA DELLA SARDEGNA

Calculation Summary

0

0-8-0

NAWAMED

■ Calculation Sur	mmary (1: Base)						×
🖻 🖹 🚧 😮							
Time (hours)	Balanced?	Trials	Relative Flow Change	Flow Supplied (m³/h)	Flow Demanded (m ³	Flow Stored (m³/h)	
All Time Steps(1)	True	6	0.0003275	461.15	461.15	0.00	
0.00	True	6	0.0003275	461.15	461.15	0.00	
Information Status	Messages Trial	s Intra-Trial S	tatus Messages Run St	tatistics			
Time Step	Element ID	Message					
Show this dialog	after Compute				Activa	ate Windows	







Determination and quantification of NRW

Table illustrate NRW measurements and calculations

Intervention	Remarks	NRW%
Isolation (baseline)	Hydraulic isolation of 10 districts in DZ- 33	36%
Water meter replacement	Replacement of 1,041 mechanical water meters to E33 -DZIN ultrasonic	27%
Rehabilitation, leak detection campaign	Broken lines, illegal use	24.6%
	4	Nor of







Summary of DZ 33 flow balance results

As it is indicated in table, the NRW values baseline at Yadoudeh area (DZ33) was 36.3% in 2016 then decreased to 24.6% at the end of 2017 after the rehabilitation works made, then increased to (40-50) % at the beginning of 2019.

the second se				
DMA	MONTH	NRW%		
	2016			
DZ 33E	Aug-16	36.30%		
DZ 33E	Sep-16	36.00%		
DZ 33E	Oct-16	36.60%		
DZ 33E	Nov-16	24.70%		
	2017			
DZ 33E	Jun-17	23.85%		
DZ 33E	Dec-17	24.63%		
	2018			
DZ 33E	Feb-18	28.19%		
DZ 33E	May-18(1/5-9/5)018	37.05%		
DZ 33 E	May-18(21/5-28/5)018	25.09%		
DZ 33E	May-18(30/5/018)	35.16%		
DZ 33E	Aug-18	28.25%		
DZ 33E	Nov-18	30.25%		
	2019			
DZ 33E	Jan-19	50%		
DZ 33E	Feb-19	38%		
DZ 33E	Mar-19	45%		
DZ 33E	Apr-19	42%		
	17. 20			







Hydraulic modeling using Water GEMS software

In this field and to reduce NRW value, new hydraulic model using Water GEMS software, is suggested by the researcher.

New hydraulic model includes a lot of corrective actions for district E:

- Redefining E district boundaries by dividing E districts to 4 DMAs E1, E2, E3, and E4 with individual main feeder for each one.
- 150 mm Poly Ethylene (PE) pipe was proposed as main feeder at the entrance of district E3 including probability of future expansion in district.
- New water meter were added at the entrance of proposed districts E1, E2, E4.
- Two Pressure Reducer Valves (PRV) was added at the proposed district E1 and the entrance of E3.







New boundaries of district E. Its worked through the Water GEMS software

33C2 33D2 F4 Ei E2 E3 з 33E 33D1 00 33D1









Elevations of the proposed districts

DMA name	Custom ers	Highest elevation (m)	Lowest elevation (m)	Difference in elevation within district (m)	Reservoir Elevation (m)	Static head (m) max. Elevation	Static head (m) min. Elevation
E1	236	850	825	25	911	86	61
E2	197	845	819	26	911	92	66
E3	476	854	818	36	911	93	57
E4	317	883	830	53	911	81	28

Average& peak demand of the proposed districts of E in DZ 33

DZ nam e	Custome rs from GIS	No. of perso ns	Populati on 2020	Current demand (L/D)	Average current demand (m³/hr)	Peak dema nd (m ³ /hr)	No. of junctio ns	Average deman d /junctio n	Peak demand/ junction
E1	236	1,274	1428	285571	12	42	20	0.59	2.08
E2	197	1,064	1192	238379	10	35	9	1.10	3.86
E3	476	2,570	2880	575982	24	84	34	0.71	2.47
E4	317	1,712	1918	383585	16	56	24	0.67	2.33







The proposed schematic diagram of DZ33



0300.





It can be seen from the tables below, after the implementation of the correct

parameters, the pressure decreased from 8.5 bar to (2-6) bar

Flex table-Pipe table of E4

	ID	Label	Length (Scaled) (m)	Start Node	Stop Node	Diameter (mm)	Material	zen-Williar C	Has Check Valve?	Minor Loss Coefficient (Local)	Flow (m³/h)	Velocity (m/s)	Headloss Gradient (m/m)	Has User Defined Length?	Length (User Defined) (m)	Age (Calculated) (hours)	Age (Maximum)	Is Active?
389: E4-13	389	E4-13	3	E4-5	E4-8	50.0	PE	130.0		0.000	1.76	0.25	0.002		0	(N/A)	(N/A)	▼
4581: E4-14	4581	E4-14	71	E4-21	E4-22	50.0	PE	130.0		0.000	-1.76	0.25	0.002		0	(N/A)	(N/A)	v
5548: E4-15	5548	E4-15	64	E4-9	E4-2	50.0	PE	130.0		0.000	1.76	0.25	0.002		0	(N/A)	(N/A)	v
8413: E4-16	8413	E4-16	101	E-27	E4-10	50.0	PE	130.0		0.000	-1.76	0.25	0.002	7	101	(N/A)	(N/A)	
8435: E4-17	8435	E4-17	172	E4-16	E4-20	50.0	PE	130.0		0.000	-1.76	0.25	0.002	v	177	(N/A)	(N/A)	v
9675: E4-18	9675	E4-18	49	E4-15	E4-8	50.0	PE	130.0		0.000	-1.76	0.25	0.002		0	(N/A)	(N/A)	▼
9676: E4-19	9676	E4-19	3	E4-8	E4-5	50.0	PE	130.0		0.000	-1.76	0.25	0.002		0	(N/A)	(N/A)	v
9686: E4-20	9686	E4-20	91	E4-13	E4-17	50.0	PE	130.0		0.000	1.76	0.25	0.002		0	(N/A)	(N/A)	v
9713: E4-21	9713	E4-21	72	E4-4	E4-3	50.0	PE	130.0		0.000	-1.76	0.25	0.002		0	(N/A)	(N/A)	v
1809: E4-6	1809	E4-6	8	E4-10	E4-11	100.0	PE	130.0		0.000	-3.53	0.12	0.000		0	(N/A)	(N/A)	V
5590: E4-10	5590	E4-10	65	E4-23	E-7	100.0	PE	130.0		0.000	-5.29	0.19	0.001		0	(N/A)	(N/A)	v
8541: E4-7	8541	E4-7	12	E4-12	E4-13	100.0	PE	130.0		0.000	3.53	0.12	0.000	V	12	(N/A)	(N/A)	v
8581: E4-8	8581	E4-8	18	E4-5	E4-3	100.0	PE	130.0		0.000	3.53	0.12	0.000	▼	18	(N/A)	(N/A)	v
9095: E4-2	9095	E4-2	167	E-98	E4-23	100.0	PE	130.0		0.000	-1.76	0.06	0.000		0	(N/A)	(N/A)	V
9096: E4-3	9096	E4-3	317	E4-23	E4-6	100.0	PE	130.0		0.000	1.76	0.06	0.000		0	(N/A)	(N/A)	v
9602: E4-12	9602	E4-12	265	E4-1	E4-7	100.0	PE	130.0		0.000	6.35	0.22	0.001	>	265	(N/A)	(N/A)	v
9634: E4-23	9634	E4-23	2	E4-7	E4-5	100.0	PE	130.0		0.000	8.82	0.31	0.001	v	2	(N/A)	(N/A)	V
10301: E4-27	10301	E4-27	56	E4-14	E4-12	100.0	PE	130.0		0.000	14.83	0.52	0.004	▼	56	(N/A)	(N/A)	▼
10499: E4-24	10499	E4-24	5	E4-12	E4-11	100.0	PE	130.0		0.000	9.53	0.34	0.002	>	5	(N/A)	(N/A)	V
10500: E4-9	10500	E4-9	53	E4-11	E4-7	100.0	PE	130.0		0.000	4.24	0.15	0.000	v	54	(N/A)	(N/A)	V
11793: E4-22	11793	E4-22	493	J-4423	E4-1	100.0	PE	130.0		0.000	6.51	0.23	0.001	₹	493	(N/A)	(N/A)	V
9757: E4-5	9757	E4-5	40	E4-9	E4-14	100.0	DI	120.0		0.000	-5.14	0.18	0.001		0	(N/A)	(N/A)	V
10892: E4-4	10892	E4-4	63	E4-18	E4-20	100.0	DI	120.0		0.000	-1.76	0.06	0.000	7	63	(N/A)	(N/A)	v
11253: E4-11	11253	E4-11	95	E4-20	E4-22	100.0	DI	120.0		0.000	-5.29	0.19	0.001	₹	95	(N/A)	(N/A)	V
11738: E4-1	11738	E4-1	119	E4-1	E4-9	100.0	DI	120.0		0.000	-1.61	0.06	0.000	▼	119	(N/A)	(N/A)	▼
11795: E4-25	11795	E4-25	5	E4-22	E4-24	100.0	Ductile 1	130.0		0.000	8.64	0.31	0.001		0	(N/A)	(N/A)	V
11798: E4-28	11798	E4-28	294	E4-19	E4-14	100.0	DI	120.0		0.000	21.73	0.77	0.009	V	292	(N/A)	(N/A)	V
11799: E4-26	11799	E4-26	3	E4-24	E4-19	100.0	Ductile 1	130.0		0.000	8.64	0.31	0.001		0	(N/A)	(N/A)	







NAWAMED Flex table- Junction table of E4

FlexTable: Junction Table (Current Time: 0.000 hours) (DZ33-ONLY E..wtg)

⚠ 🔓 ▾ 🛱 📝 🍳 👭 📄 ▾ 🐺 ▾ 🛝 ▾

	ID	X (m)	Y (m)	Label	Elevation (m)	Zone	Demand Collection	Demand (m²/h)	Hydraulic Grade (m)	Pressure (bars)	Is Active?
5441: E4-1	5441	235,872.54	140,517.51	E4-1	861.00	E	<collection:< td=""><td>1.76</td><td>888.44</td><td>2.69</td><td>V</td></collection:<>	1.76	888.44	2.69	V
5549: E4-2	5549	235,928.25	140,375.07	E4-2	858.00	E	<collection:< td=""><td>1.76</td><td>888.32</td><td>2.97</td><td>V</td></collection:<>	1.76	888.32	2.97	V
1576: E4-3	1576	236,081.78	140,482.50	E4-3	855.53	E	<collection:< td=""><td>1.76</td><td>888.23</td><td>3.20</td><td>▼</td></collection:<>	1.76	888.23	3.20	▼
6068: E4-4	6068	236,145.20	140,517.09	E4-4	855.00	E	<collection:< td=""><td>1.76</td><td>888.08</td><td>3.24</td><td>v</td></collection:<>	1.76	888.08	3.24	v
7800: E4-6	7800	236, 154. 19	140,524.83	E4-6	855.00	E	<collection:< td=""><td>1.76</td><td>891.01</td><td>3.52</td><td>7</td></collection:<>	1.76	891.01	3.52	7
390: E4-5	390	236,075.57	140,470.36	E4-5	854.82	E	<collection:< td=""><td>1.76</td><td>888.24</td><td>3.27</td><td>V</td></collection:<>	1.76	888.24	3.27	V
3115: E4-7	3115	236,073.51	140,469.20	E4-7	854.75	E	<collection:< td=""><td>1.76</td><td>888.24</td><td>3.28</td><td>V</td></collection:<>	1.76	888.24	3.28	V
391: E4-8	391	236,077.05	140,468.27	E4-8	854.69	E	<collection:< td=""><td>1.76</td><td>888.23</td><td>3.28</td><td>V</td></collection:<>	1.76	888.23	3.28	V
2387: E4-9	2387	235,952.16	140,434.75	E4-9	854.00	E	<collection:< td=""><td>1.76</td><td>888.45</td><td>3.37</td><td>7</td></collection:<>	1.76	888.45	3.37	7
1810: E4-10	1810	236,024.41	140,447.69	E4-10	853.50	E	<collection:< td=""><td>1.76</td><td>888.26</td><td>3.40</td><td>7</td></collection:<>	1.76	888.26	3.40	7
1811: E4-11	1811	236,028.58	140,440.90	E4-11	853.09	E	<collection:< td=""><td>1.76</td><td>888.26</td><td>3.44</td><td>V</td></collection:<>	1.76	888.26	3.44	V
1063: E4-12	1063	236,024.00	140,438.03	E4-12	852.93	E	<collection:< td=""><td>1.76</td><td>888.27</td><td>3.46</td><td>v</td></collection:<>	1.76	888.27	3.46	v
1600: E4-13	1600	236,032.87	140,437.95	E4-13	852.92	E	<collection:< td=""><td>1.76</td><td>888.27</td><td>3.46</td><td>7</td></collection:<>	1.76	888.27	3.46	7
363: E4-14	363	235,978.76	140,405.06	E4-14	852.00	E	<collection:< td=""><td>1.76</td><td>888.48</td><td>3.57</td><td>7</td></collection:<>	1.76	888.48	3.57	7
5001: E4-15	5001	236,105.60	140,428.07	E4-15	849.00	E	<collection:< td=""><td>1.76</td><td>888.13</td><td>3.83</td><td>V</td></collection:<>	1.76	888.13	3.83	V
6091: E4-16	6091	236, 195.55	140,414.35	E4-16	846.00	E	<collection:< td=""><td>1.76</td><td>890.59</td><td>4.36</td><td>v</td></collection:<>	1.76	890.59	4.36	v
2330: E4-18	2330	236,064.32	140,315.80	E4-18	845.00	E	<collection:< td=""><td>1.76</td><td>890.96</td><td>4.50</td><td>v</td></collection:<>	1.76	890.96	4.50	v
6458: E4-17	6458	236,087.33	140,365.11	E4-17	845.00	E	<collection:< td=""><td>1.76</td><td>888.08</td><td>4.22</td><td>7</td></collection:<>	1.76	888.08	4.22	7
11796: E4-19	11796	236,172.03	140, 193.20	E4-19	842.08	<none></none>	<collection:< td=""><td>0.00</td><td>891.01</td><td>4.79</td><td>V</td></collection:<>	0.00	891.01	4.79	V
1061: E4-20	1061	236,106.42	140,268.91	E4-20	841.00	E	<collection:< td=""><td>1.76</td><td>890.96</td><td>4.89</td><td>1</td></collection:<>	1.76	890.96	4.89	1
3808: E4-21	3808	236,122.86	140,147.06	E4-21	837.00	E	<collection:< td=""><td>1.76</td><td>890.87</td><td>5.27</td><td>V</td></collection:<>	1.76	890.87	5.27	V
1761: E4-22	1761	236,171.40	140,199.30	E4-22	834.00	E	<collection:< td=""><td>1.76</td><td>891.02</td><td>5.58</td><td>1</td></collection:<>	1.76	891.02	5.58	1
11794: E4-24	11794	236,174.76	140, 195. 12	E4-24	833.00	<none></none>	<collection:< td=""><td>0.00</td><td>891.02</td><td>5.68</td><td>V</td></collection:<>	0.00	891.02	5.68	V
5591: E4-23	5591	236,234.98	140,221.54	E4-23	831.00	E	<collection:< td=""><td>1.76</td><td>891.03</td><td>5.88</td><td>V</td></collection:<>	1.76	891.03	5.88	V

Calculation summary

As the calculation summary show in Figure below, peak flow supplied=flow demanded= $1614m^3/hr$ and its very close to the calculated demanded = $1618m^3/hr$.

Calculation Summary (11810: PEAK)

h 🗎 📈 😮

ime (nours)	Balanced?	Trials	Relative Flow Change	Flow Supplied (m³/h)	Flow Demanded (m ³	Flow Stored (m ³ /h)
All Time Steps(1)	True	7	0.0001056	1,614.04	1,614.04	0.00
0.00	True	7	0.0001056	1,614.04	1,614.04	0.00
information Status	Messages Tri	als Intra-Trial S	Status Messages Run St	atistics		
nformation Status Time Step	Messages Tri Element ID	als Intra-Trial S Message	Status Messages Run St	atistics		







AWWA analysis



Water balance in Yadoudeh (DZ33) distribution network

- According to the water balance of the case study Yadoudeh (DZ33), the total water been supplied was about 2.929 MCM while the total billed consumption amounts to 1.784 MCM.
- The Non-Revenue Water for DZ33 is 26.1% in 2018 which constitutes about 0.765 MCM. As it can be inferred that the model shows that 0.382 MCM (64%) of water losses are real losses while 0.216 MCM (36%) accounts for apparent losses.







REGIONE AUTÒNOMA DE SARDIGNA REGIONE AUTONOMA DELLA SARDEGNA

NAWAMED





NON-REVENUE WATER 764.628 ML/Yr NON-REVENUE VATER: = Water Losses + Unbilled Metered + Unbilled Unmetered SYSTEM DATA Length of mains: 🔸 📪 👔 335.8 kilometers 5,400 Number of active AND inactive service connections: -- 7 9 Service connection density: 16 conn./km main Are customer meters typically located at the curbstop or property line? (length of service line, beyond the property Average length of customer service line: 🔛 🔼 💦 8.0 metres boundary, that is the responsibility of the utility) 85.0 metres (head) Average operating pressure: + 👔 💦 COST DATA Total annual cost of operating water system: 💽 🗾 👔 \$2,646,665 \$/Year Customer retail unit cost (applied to Apparent Losses): 📩 🔼 👔 \$0.86 \$/1000 litres Variable production cost (applied to Real Losses): 📩 🔼 💦 \$6.62 \$/Megalitre Use Customer Retail Unit Cost to value real losses

WATER AUDIT DATA VALIDITY SCORE:

*** YOUR SCORE IS: 67 out of 100 ***

A weighted scale for the components of consumption and water loss is included in the calculation of the Water Audit Data Validity Score

PRIORITY AREAS FOR ATTENTION:

Based on the information provided, audit accuracy can be improved by addressing the following components:

1: Volume from own sources

2: Billed metered

3: Customer metering inaccuracies







The water balance in DZ 33 (Yadoudeh) distribution network

		Wate	r Audit Report for:	Miyahuna-Jordan Water Company	,	
			Reporting Year:	2018	1/2018 - 12/2018	
		D	ata Validity Score:	67		
		Water Exported 0.000			Billed Water Exported	Revenue Water 0.000
				Billed Authorized Consumption	Billed Metered Consumption (water exported is removed)	Revenue Water
			Authorized		1,784.200	
Own Sources (Adjusted for			Consumption	2,164.652	Billed Unmetered Consumption 380.452	2,164.652
known errors)			2,331.479	Unbilled Authorized Consumption	Unbilled Metered Consumption 130.211	Non-Revenue Water (NRW)
2,929.280				166.827	Unbilled Unmetered Consumption	5
			•		36.676	
	System Input	Water Supplied			Unauthorized Consumption	/64.628
	2,929.280	2 929 280		Apparent Losses	7.323 Customer Metering Inaccuracies	
		2,020.200		210.000	204.109	
					Systematic Data Handling Errors	
			Water Losses		4.461	
Water Imported			597.801	Real Losses	Leakage on Transmission and/or Distribution Mains Not broken down	
0.000				381.908	Leakage and Overflows at Utility's Storage Tanks	
					Not broken down	
					Leakage on Service Connections Not broken down	









System attributes and performance indicators of DZ33 (Yadoudeh) distribution network

*	AWWA Free Water Audit So System Attributes and Performan	ftware: ice Indicators	WAS v5.0 American Water Works Association. Copyright © 2014, All Rights Reserved.
	Water Audit Report for:Miyahuna-Jordan Water CompaReporting Year:20181/2018 - 12/2018	any	
	*** YOUR WATER AUDIT DATA VALIDITY SCORE	IS: 67 out of 100 ***	Deterto Desido Midde de la desidad
Performance Indicators			Return to Reporting Worksheet to change this assumption
Einancial	Non-revenue water as percent by volume of Water Supplied:	26.1%]
Filidificial.	Non-revenue water as percent by cost of operating system:	7.2%	Real Losses valued at Variable Production Cost
Γ	Apparent Losses per service connection per day:	109.53	litres/connection/day
Operational Efficiency:	Real Losses per service connection per day:	N/A	litres/connection/day
operational Enciency.	Real Losses per length of main per day*:	3,116.19	litres/km/day
Real Lo	osses per service connection per day per meter (head) pressure:	N/A	litres/connection/day/m
F	rom Above, Real Losses = Current Annual Real Losses (CARL):	381.91	ML/year
	? nfrastructure Leakage Index (ILI) [CARL/UARL]:	1.08	
* This performance indicator applies f	or systems with a low service connection density of less than 20 ser	vice connections/kilometre	of pipeline







Real loss component analysis

NAWAMED

Summary of real loss component analysis

REAL LOSS COMPONENT ANALY	SIS RESULTS			
System Component	Background Leakage	Reported Failures	Unreported Failures	Total
	(ML)	(ML)	(ML)	(ML)
Reservoirs	-	-	-	
Mains and Appurtenances	131.48	45.56	-	177.02
Service Connections	160.31	89.83	-	250.14
Total Annual Real Loss	291.77	135.40	•	427.17
	Real Losse:	s as Calculated	by Water Audit	381.91
Hide	den Losses/Unreported Leakage C	Currently Runni	ng Undetected -	45.26





Failure frequency analysis



The Infrastructure failure frequency analysis here in main pipes and service connections for water distribution network in Yadoudeh in comparison with the average failure frequency in North America is indicated in Figures below.

WaterRF 4372: Real Loss Component Analysis: A Tool for Economic Water Loss Control

Water Audit: Jordan-Miyahuna, Amman, Jordan, 2018 INFRASTRUCTURE FAILURE FREQUENCY ANALYSIS

Jordan-Miyahuna	l	
Total Number of Mains Failures Reported for Water Audit: Jordan- Miyahuna, Amman, Jordan, 2018	185	
Total Length of Mains	335.8	(kilometers)
Failure Frequency Jordan-Miyahuna	55.1	(number /100kilometers / yr)
Average Failure Frequency in North America Based on Literature Review - WaterRF 4372	15.5	(number /100kilometers / yr)
Failure Frequency for Optimized Distribution Systems (Friedman 2010)	9.3	(number /100kilometers / yr)



Jordan-Miyahuna		
Total Number of Service Connection Failures Reported for Water Audit: Jordan-Miyahuna, Amman, Jordan, 2018	549	
Total Number of Service Connections	5,400	(service connections)
Service Connection Failure Frequency Jordan-Miyahuna	101.7	(number / 1000 service connections / yr)
AWWA Unavoidable Annual Real Losses (UARL) Component of Reported Service Line Failures	3.75	(number / 1000 service connections / yr)
Ratio of Failure Frequency to UARL Break Frequency	27.1	

Value to be entered by the use

Recommended default value

Value is automatically filled in/calculated by Mode







NAWAMED Awareness -location- repair time options for DZ33 (Yadoudeh)

Figure below show the total potential savings if location and repair time in the failures on main pipes and service connections is reduced to (30-50)% The total potential savings in leakage volume will be 0.062 MCM with a total potential cost savings is 407 USD.

Reported and Unreported Failure Events				Failures on System Appurtenances	Reported	Unreported	
Failures on Mains	Reported	Unreporte	d	Total Number of Failures on System Appurtenances in 2018		•	
Total Number of Failures on Mains in 2018	18	5 -		Average location and repair duration		•	days
Average location and repair duration	1.	0 -	days	Total Volume lost (stemming from location and repair duration)			(ML)
Total Volume lost (stemming from location and repair duration)	36.	5 -	(ML)	Total Cost of Volume Lost (stamming from location and rapair duration)	\$	\$	
Total Cost of Volume lost (stemming from location and repair duration)	\$ 241	\$ -		Total Cost of Volume lost (stemming from location and repair duration)	V	V	
What IF Location and Repair Duration is Reduced to	0	3	days	What IE Location and Bonair Duration is Boduced to			dave
Percent Reduction	709	6	0%		00/	00/	uays
Potential Related Savings in Leakage Volume	25.	5 -	(ML)	Percent Heduction	0%	0%)
Potential Related Savings in Leakage Volume Cost	\$ 169	\$ -		Potential Related Savings in Leakage Volume	•	•	(ML)
				Potential Related Savings in Leakage Volume Cost	ş -	ş -	
Service Line Failures	R eported	Unreporte	d				
Total Number of Failures on Service Connections in 2018	54	9.		The Devention of the sector of Development of Development			
Average location and repair duration	1.	0 -	days	Total Potential Savings if Location and Repair Duration is Reduced as	61.4		(ML)
Total Volume lost (stemming from location and repair duration)	71.	9 -	(ML)	Simulated in the Above Sections			\···-/
Total Cost of Volume lost (stemming from location and repair duration)	\$ 476	\$-		Total Potential Cost Savings if Location and Repair Duration is	¢ 407	*	D V
				Reduced as Simulated in the Above Sections	ə 407	۰ ،	Per Year
What IF Location and Repair Duration is Reduced to	0.	5	days				
Percent Reduction	50%	6	0%				
Potential Related Savings in Leakage Volume	35.	9 -	(ML)	14.10.19	@2014 Water Re	search Foundatio	
Potential Related Savings in Leakage Volume Cost	\$ 238	\$ -			OLUTY WAIGHT	over of Frontideut	n. ALL DIVIETO







Economic intervention frequency

NAWAMED

The calculation of economic intervention frequency for proactive leak detection

/aterRF 4372:	Real Loss Component Analysis: A Tool for Economic Water Loss Control			Variable Cost of Real Losses	
			CV	Variable Production cost (applied to Re	al Losses): 0.01 \$/m3
/ater Audit: Jo	ordan-Mivahuna, Amman, Jordan, 2018		1		6.62 \$/ML
	I OF ECONOMIC INTERVENTION ERECTIENCY FOR PROACTIVE LEAK DETECTION	N N N N N N N N N N N N N N N N N N N]		
		•	•]		
	Queter Observation		CI	Cost of comprehensive leak detection survey (excluding leak re	epair cost) 90.00 \$/km
	System Characteristics				30,222 \$/for entire system
	Total Length of Mains	335.8 kilometers			
	Number of Service Connections	5,400 service connections	RR	Average Rate of Rise of Unreported	J Leakage 3.00 m3/km of mains/day in a year
	Service Connection Density	16.1 conn./kilometer main			1.01 ML/day in a year
	Average System Pressure	85.0 metres (head)			CHOV 19505.0 m9/km
	Water Balanco Deculte		FIF	Economic Intervention Frequency (0.789 * (CI/CV)	/RRI ^ 0.5 59.8 months
трі	Ourset Annual Bestaround Leokene	001 77 MI M-			1.818.8 days
IDL	Current Annual Background Leakage	291.77 ML/11		Economic Intervention Frequency - Average Leak	Run Time 909.4 days
CRL	Real Losses from Current Reported Leakage	135.40 ML/Yr		Economic Percentage of System to be Surveyer	d per Year 20 %
UL	Unreported Failures Identified Through Existing Proactive Leak Detection Program	- ML/Yr	1		·
	Hidden Failures/Unreported Failures not Identified or Captured by Current Leakage	45.00	ABI	Average Annual Budget for Intervention (Proactive Leak	Detection) 6,065 \$/year
	Management Policy	- 40.26 ML/Yr]		
			EUL	Economic Unreported R	eal Losses 916,171 m3/year
CARI	Current Annual Real Losses	381 91 MI /Vr			916.2 ML/year
	Univid Annual Iva Luada	001.01 ML/11		Economic Infrastructure Leakage	Index (ILI) 3.8
UAKL	Unavoidadie Annuai Meai Losses	300.06 ML/Yr			
	Infrastructure Leakage Index (ILI) [CARL/UARL]	1.1	PRL	Potentially Recoverable Leakage (CARL-CRL-EU	/L-TBL-UL) - 961.4 ML/year









Pressure management options

NAWAMED

The estimated cost for the implementation of the alternative pressure management policy in order to minimize the pressure to 50 meters head is almost 4 million USD. The simple payback Period for implementing alternative pressure management policy is 2.7 years.

Pressure management has an effect of the volume of real losses. Also it has another benefits and impacts such as; reduction in infrastructure failure numbers, reduction in the annual cost of repair and maintenance, increasing infrastructure lifetime.

	Existing Pressure Management Policy	_
Current Average System Pressure	85.0	metres (head)
Total Annual Real Losses	381.9	ML/Yr
Value of Real Losses	2,528	\$/year

FAVAD N1 Value Used for Calculation of Real Loss Reduction Due to Reduction of Average System Pressure

Pressure Management Opportunities



50.0 metres (head) 59% 224.7 ML/Yr 1,487 \$/Year
59% 224.7 ML/Yr 1,487 \$/Year
224.7 ML/Yr 1,487 \$/Year
1, <mark>4</mark> 87 \$/Year







REGIONE AUTONOMA DE SARDIGNA REGIONE AUTONOMA DELLA SARDEGNA



Conclusions and Recommendations







Conclusions



- The NRW values base line 36.3% in 2016 then decreasing to reach 24.63% at the end of 2017 after rehabilitation works then increase to (40- 50)% at the beginning of 2019.
- New hydraulic model is proposed using Water GEMS software aim to reduce pressure values from 85bar to (2-6) bar.
- DZ-33 was further subdivided to additional districts, Because of the redistricting, the number of DZ- 33 districts increased from 8 to 10 according to original hydraulic analysis model and from 10 to 13 according to new proposed model.
- Leakage frequencies are so significant in Yadoudeh which indicates to low efficiency of the distribution system. About 95 % of leaks are recorded in the service connections in which pipe diameters are less than 100 mm and most of the leaks took place in polyethylene.
- DZ 33 (Yadoudeh) water balance was developed based on AWWA water audit software according to the data provided to the model its revealed that the total water supplied about 3 MCM while the total billed consumption amounts to 1.784 MCM.







Conclusions



- > The Non-Revenue Water for DZ33 in 2018 constitutes about 0.765 MCM.
- As it can be inferred that the model shows that 64% of water losses are real losses while 36% accounts for apparent losses.
- The component analysis found that the total annual reported losses in main pipes are 0.045 MCM while the total reported losses in service connections are 0.090 MCM
- The estimated cost for the implementation of the alternative pressure management policy in order to minimize the pressure to 50 meters head is almost 4 million USD. The simple payback Period for implementing alternative pressure management policy is 2.7 years.







Recommendations



- There is need to identified water loss areas at distribution areas of the network in other areas to conserve water in Jordan.
- It is recommended to automate the data collection process in the distribution network that can be simply ease the work and enhance the data accuracy. Updating GIS maps have also a critical impact on data analysis.
- The hotspots area located in district E. so it's recommended to make cross sections at the borders of E1, E2, E3, E4 districts including excavation works to determine if there is any pipes at location and not identify in the drawings.
- It is recommended instead of rehabilitating the entire network to apply systematic pipe replacements.
- It is recommended to increase the accuracy of meters and billing system through the other districts of DZ 33 and applying automatic meter reading (AMR)







REGIONE AUTÒNOMA DE SARDIGNA REGIONE AUTONOMA DELLA SARDEGNA



